

WEST VIRGINIA LEGISLATURE

2023 REGULAR SESSION

Introduced

House Bill 2186

By Delegate Mallow

[Introduced January 11, 2023; Referred to the
Committee on Health and Human Resources]

1 A BILL to amend the Code of West Virginia, 1931, as amended, by adding thereto a new section,
2 designated §16-5B-20, relating to requirements for smoke evacuation systems for health
3 care facilities; defining terms; and creating penalties for violation of requirement.

Be it enacted by the Legislature of West Virginia:

ARTICLE 5B. HOSPITALS AND SIMILAR INSTITUTIONS.

§16-5B-20. Smoke evacuation system required for certain surgical procedures.

1 (a) As used in this section:

2 (1) "Energy generating device" means any tool that performs a surgical function using
3 heat, laser, electricity, or another form of energy;

4 (2) "Smoke evacuation system" means smoke evacuators, laser plume evacuators, or
5 local exhaust ventilators that effectively capture and neutralize surgical smoke at the site of origin
6 and before the smoke can make ocular contact or contact with the respiratory tract of the
7 occupants of the room; and

8 (3) "Surgical smoke" means the by-product, including surgical plume, smoke plume, bio-
9 aerosols, laser-generated airborne contaminants, and other lung-damaging dust, that results from
10 contact with tissue by an energy generating device.

11 (b) On or before January 1, 2024, in order to protect operating room nurses, operating
12 room personnel, and patients from the hazards of surgical smoke, the secretary shall propose
13 rules for legislative approval in accordance with the provisions of §29A-3-1 et seq. of this code
14 requiring a health care facility licensed under this chapter that utilizes energy generating devices
15 to use a smoke evacuation system during any surgical procedure that is likely to produce surgical
16 smoke.

17 (c) Any health facility acting by or through its agents or employees that violates subsection
18 (b) of this section shall be punished by a fine of not less than \$100 nor more than \$500 for each
19 violation.

Introduced HB 2186

NOTE: The purpose of this bill is to ensure that a smoke evacuation system is in place to protect medical personnel during any medical treatment where there could be surgical smoke.

Strike-throughs indicate language that would be stricken from a heading or the present law and underscoring indicates new language that would be added.